

**REQUEST FOR TENDER PS-2018-02**

***FUEL SYSTEM CODE COMPLIANCE***

***[POPLAR LODGE PARK & HIGH HILL HARBOUR MARINA]***

**ADDENDUM #1**

***ISSUED BY***

**THE CORPORATION OF THE MUNICIPALITY OF GREENSTONE**

**P.O. BOX 70, 1800 MAIN STREET  
GERALDTON, ON POT 1M0  
TEL: [807] 854-1100  
FAX: [807] 854-1947**

**THIS ADDENDUM FORMS AND BECOMES PART OF TENDER PS-2018-02.**

## **ADDENDUM #1**

### **TENDER FOR FUEL SYSTEM CODE COMPLIANCE UPGRADES [POPLAR LODGE PARK & HIGH HILL HARBOUR MARINA] MUNICIPALITY OF GREENSTONE**

**PAGE 1 OF 2**

APRIL 23, 2018

Question 1 of 6 as posed:

#### Question #1

Can you include in the scope of work to replace exhaust piping as required?

#### Answer #1

Yes. The scope of work shall include the replacement of exhaust piping as required.

#### Question #2

Can you tell us what the wall construction is? 2' x 6" wood or concrete blocks?

#### Answer #2

The wall construction is concrete block.

#### Question #3

Do you presently have a wall thimble?

#### Answer #3

Only the system at Poplar Lodge Park appears to have a wall thimble. It needs to be verified as being code compliant.

## **ADDENDUM #1**

### **TENDER FOR FUEL SYSTEM CODE COMPLIANCE UPGRADES (POPLAR LODGE PARK & HIGH HILL HARBOUR MARINA) MUNICIPALITY OF GREENSTONE**

**PAGE 2 OF 2**

April 23, 2018

#### Question #4

What is the exhaust pipe diameter for the two systems?

#### Answer #4

The systems appear to have variable diameter sections including flexible and rigid piping with diameters in between three and four inches.

#### Question #5

Is the ventilation fixed (manual) or is it automatic damper controlled.

#### Answer #5

Both systems have manual intake and exhaust ventilation.

#### Question #6

I have the "Instructions to Bidders" tender document, but not the Comprehensive Inspection Reports or any photographs.

#### Answer #6

The inspection reports are posted on the municipal website as a separate document. Four photos have also been posted on the Tenders webpage.

#### Additional Notes:

The tender document on the municipal website has been updated with a reformatted version. The Tender Form now displays correctly on two pages.