



February 19, 2019

Mayor Renald Beaulieu and Council
The Corporation of the Municipality of Greenstone
P.O. Box 70
Geraldton, Ontario
P0T 1M0

Re: 2018 Annual Summary Report for the Beardmore Drinking-Water System
2018 Annual Summary Report for the Caramat Drinking-Water System
2018 Annual Summary Report for the Geraldton Drinking-Water System
2018 Annual Summary Report for the Longlac Drinking-Water System
2018 Annual Summary Report for the Nakina Drinking-Water System

Ontario's Drinking-Water Systems Regulation (O.Reg.170/03), made under the *Safe Drinking Water Act, 2002*, requires that the owner of a drinking water system prepare an annual summary for municipalities on the operation of the system and the quality of its water.

The annual summary must cover the period of January 1st to December 31st in a year and must *be prepared not later than March 31st* of the following year. Pursuant to the legislative requirements, enclosed for your records is the 2018 Annual Summary for the Greenstone Drinking-Water Systems.

Pursuant to the legislative requirements, *Schedule 22 Summary Reports for Municipalities*, the annual summary must:

- (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and,
- (b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure."

- O. Reg. 170/03 s. 22 (2)

"The report must also include the following information for the purpose of enabling the owner of the system to assess the rated capability of their system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water licence, or if the system is receiving all of its water from another system under an

agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.”

-O. Reg. 170/03 s. 22 (3)

In addition, Section 12 (1) - 4 - gives the direction that a copy of the annual summary for the system is given, without charge, to every person who requests a copy and be made available for inspection by any member of the public during normal business hours. The reports should be made available at the office of the municipality, or at a location that is accessible to the users of the water system.

These reports were prepared by the Ontario Clean Water Agency on behalf of the Corporation of the Municipality of Greenstone and are based on information kept on record by OCWA at each specific water treatment plant. The report covers the period January 1st through to December 31st 2018.

Yours truly,



Bradley McMahon
Senior Operations Manager
Northwestern Ontario Regional Hub

Copy to: Mark Wright - CAO
Brian Aaltonen – Director of Public Services
Operations Staff – Beardmore WTP
Operations Staff – Caramat WTP
Operations Staff – Geraldton WTP
Operations Staff – Longlac WTP
Operations Staff – Nakina WS

2018 Schedule 22 Annual Summary Report

Nakina Drinking-Water System

February 2019

Prepared by the



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Table of Contents

Section 1: Introduction2

Section 2: What Does This Report Contain?2

Section 3: Daily Flow Rates3

Section 4: System Failures and Corrections5

Section 5: Conclusion5

Section 1: Introduction

This report is a summary of water quality information for the Nakina Drinking-Water System, published in accordance with Schedule 22 of Ontario’s Drinking-Water Systems Regulation for the reporting period of January 1st to December 31st 2018. The Nakina Drinking-Water System is categorized as a Large Municipal Residential Drinking Water System.

This report is prepared by The Ontario Clean Water Agency on behalf of the Corporation of the Municipality of Greenstone – Nakina Ward. A copy of the Summary Report is to be provided to the members of the municipal council by March 31st 2019.

Section 2: What Does This Report Contain?

“The report must,

- (a) list the requirements of the Act, the regulations, the system’s approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and,
- (b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.”

- O. Reg. 170/03 s. 22 (2)

“The report must also include the following information for the purpose of enabling the owner of the system to assess the rated capability of their system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system’s approval, drinking water works permit or municipal drinking water licence, or if the system is receiving all of its water from another system under an agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.”

-O. Reg. 170/03 s. 22 (3)

Section 3: Daily Flow Rates

In accordance with the **Municipal Drinking Water Licence 225-103 Schedule C: System – Specific Conditions 1.0 Performance Limits**, the Nakina drinking water system shall not be operated to exceed the rated capacity for maximum flow rate from the treatment subsystem to the distribution system of **2000 m³ / day**.

The drinking water system may be operated temporarily at a rate above the rated capacity where necessary for:

- (i) the purposes of fighting a large fire or,
- (ii) the maintenance of the drinking-water system

In 2018, the average monthly raw flow rate was 7607.08 m³; the average raw daily flow rate was 250.10 m³, with a maximum raw daily flow rate of 730.00 m³.


In 2018, the average monthly treated flow rate was 7048.92 m³; the average daily treated flow was 232.29 m³ and the maximum daily treated flow for the year was 402.00 m³; this represents 20.10 % of the allowable daily volume.

A summary of raw and treated flows, including maximum raw flow into the treatment system as well as treated average, maximum and total flow rates are included in the tables below.

The quantity of raw water supplied during the reporting period did not exceed the terms and conditions of the *Permit to Take Water* nor did the treated flows directed to the distribution system exceed the rated capacity for this system.

Monthly Raw & Treated Flow Rates for 2018

Month	Average Daily Raw Flow Rate (m ³ /d)	Maximum Daily Raw Flow Rate (m ³ /d)	Average Daily Treated Flow Rate (m ³ /d)	Maximum Daily Treated Flow Rate (m ³ /d)	Total Monthly Treated Flow Rate (m ³ /month)
January	286.81	439.00	261.52	284.00	8107.00
February	331.46	450.00	306.43	338.00	8580.00
March	349.00	494.00	337.90	375.00	10475.00
April	337.50	486.00	308.70	402.00	9261.00
May	200.13	367.00	194.29	261.00	6023.00
June	235.83	416.00	208.60	295.00	6258.00
July	245.81	426.00	223.90	266.00	6941.00
August	208.81	416.00	228.00	260.00	7068.00
September	269.87	730.00	224.07	256.00	6722.00
October	163.58	416.00	137.29	257.00	4256.00
November	167.20	226.00	163.20	184.00	4896.00
December	213.35	364.00	193.55	272.00	6000.00
2018 Total Treated Flows (m ³)				84587.00	



Section 4: System Failures and Correction

The Ministry of Environment conducted an *announced* inspection of the Nakina Drinking Water System on January 23rd, 2018. There final inspection report has yet to be issued.

The 2018 final inspection rating record for the Nakina Drinking Water System was 100%.

Item	Non-Compliance Identified	Compliance Date	Action Being Taken to Address item	Status
N/A	N/A	N/A	N/A	N/A

Section 5: Conclusion

In the reporting year of 2018, there were no adverse water quality incident (AWQI) reports filed.

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A	N/A	N/A	N/A	N/A	N/A

For the operating year of 2018, the Nakina Drinking Water System was able to meet the demand of water use within the town without exceeding the Municipal Drinking Water License and Permit to Take Water.